

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7300-1615:161

Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

**DESIGN:** Model D113 Battery Supervision Module. The unit is intended to supervise and isolate two batteries connected in parallel. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 12 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as battery supervision module for use with separately listed compatible fire alarm control units.

**NOTE:** Formerly 7300-0801:192

01-05-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*